

Public Works Report

1. He had to put a new heater in well house #3. The old one was a plug in one and the plug melted and fried the outlet. I had Sullivan's put in a new hanging 240v heater that is hard wired and has a thermostat on it. It is the same kind of heater we have in well house #5.
2. Well house #3 needed a new pressure sending unit for the pump. This tells how much water is in the Water Tank and when to run the pump to fill. This was ordered and installed by Servocal Instruments. The door which was rotted and falling off the hinges was also replaced by Mike Pfarr.
3. The Well house in the park also needs a new door. The bottom is rotting out and falling of the hinges making it hard to close all the way to lock. The price for the door is \$500.00 plus \$300.00 for install. Price is higher due to it being a special size door. The door is shorter than normal. Would like to also have a heater installed In Well house #2 to help with freeze issues In the Winter. Currently there is no heater.
4. Lauritsen Septic has been contacted to come clean out grease in the Lift Station. Just waiting for them to get here. Should be done this week or next.

5. I've been talking with Electric Pump about our Omni-site issues of losing signal. They say that we need to switch to a Verizon based system instead of the AT&T one that we have. Apparently AT&T has real spotty coverage in our area and isn't strong enough to keep up with the demands. What they recommend doing is getting a 2 year contract with Omni-Site themselves for \$300.00. By doing this Omni-Site Will make the Switch for us and fix all future problems in the 2 years. After the two years are up I don't think we would need to renew then as the problems should be fixed. It's kind of like when all cell phones switched from analog to digital. It took a year or so to get all the bugs out. We could leave it as is and see if it gets better. We would still get the alarm calls according to Electric Pump. We just will have spotty data on what we are pumping and what is coming into the Lift Station.
6. I would like to get an ad in the paper for summer help A.S.A.P. Since we will be doing televising of sewer lines this summer the sooner they can start the better. Last year we lost a month waiting to place an ad and interviewing. Would recommend \$11.00 an hour pay.