

# Public Works Report

1. I got some real useful info at the conference in terms of pipe install/repair. There is a way to line the pipe with an fiberglass/epoxy resin with a polyethylene layer for smoothness. This will help reduce friction and corrosion on the pipe. I haven't gotten any price quotes yet. If the city is interested let me know and I get some. I'll leave a brochure on the council table for anyone who wants to look at it. This will work on water and wastewater pipes. Could be a great way to upgrade old water mains.
2. Just wanted to remind the council that we will no longer be able to get replacement water meters. The city will have to decide if they want to start upgrading. I can get some quotes on new ways to upgrade the system if wanted.
3. I also found a company that can do water tank cleaning without draining and shutting down the system. Won't have the potential for water breaks this way.
4. I've been able to shut the Boilers down during the day to save costs due to warmer weather. Hopefully can keep them off permanent soon.
5. I recently received a list from Tri-Valley with numerous things they would like fixed and painted in the school. Was supposed to have gotten it 3 months ago but for some reason did not. I already gotten most minor stuff fixed and am in the process of doing some painting. I contacted Randy to help with some painting when needed. He said he could help.

6. We have been having some issues with our new Omni-Site monitor. It hasn't been dialing in everyday with pump calculations and then putting them in one lump some when it does. I believe it is because of signal issues and I am working with Electric pump to resolve this issue.
7. Lift Station has been pumping within normal range and both Wells have had no problems.
8. I would like to have Lauritsen Septic from Montevideo come and clean out Lift Station. Getting some grease buildup around the edges and by pump #2