

# PUBLIC WORKS REPORT

1. I talked with Chris Young from Xcel energy and went around with him to show him some poles that were looking rough. He had those poles tested and all came back in good condition. No rot issues.
2. The new pump and motor was put in Well #5 by Thein Well. We also had to replace a phase motor protection relay and a starter motor that was chattering very badly. In the process of replacing these I had Sullivan's meg out the motor and we found that we were losing amps on one of the wires. They traced the line from the well to the well house and we found a bad spot where it had been previously spliced. It was dug up and fixed. Luckily it was only two feet down. It's good we tested or we could have prematurely burned out our new pump motor.
3. I received a quote from Excel Overhead to replace the sliding doors on the shop with an overhead one with opener for \$4177.00. I've included the quote with the report. I still have received nothing from Danube Lumber to fix the doors we have after numerous stops there.
4. Sam Lang informed me that he will not be driving truck this year due to health issues. We will need to find someone else. An ad in the Paper? Jim, Art,

and Bob should also be offered their jobs/contracts to see if they are also interested. I have not talked with them yet. Is Lonny Davis willing to run boilers when I'm gone again?

5. The bathrooms at the park have been shut down and winterized for the year.
6. We accidentally received another order of Aqua-Jolt from State Chemical. With some smooth talking I got them to basically give us the product for free. All we have to do is pay a shipping of \$40.85. The product costs \$1000.00. I say it's a good deal.
7. I was planning on taking vacation again the weeks of Nov 4-11 and Dec 23-30.